



Mr Ron Anderson
Santos Limited
300 Yarrie Lake Road Road
Narrabri NSW 2390

Contact: Heidi Watters
Phone: [REDACTED]
Email: [REDACTED]
compliance@planning.nsw.gov.au
Our Ref: MP 07_0023 (#16956)

Dear Mr Anderson

**Wilga Park Power Station
Compliance Noise Monitoring (January 2019) Report (revised)**

Reference is made to the revised Compliance Noise Monitoring (January 2019) report for the Wilga Park Power Station (WPPS) submitted by Santos Limited (Santos) to the Department of Planning and Environment (the Department) on 12 April 2019, prepared as required by with Schedule 2 conditions 2.8, 2.9 and 3.5 of MP 07_0023 (the approval).


The Department has reviewed the revised report and considers it to generally satisfy the conditions of the approval.

The noise monitoring found that at the time of the monitoring, noise measured at all receivers complied with the maximum allowable noise contribution of 35 dBA L_{Aeq}(15 minute) defined in Condition 2.8 of the approval, with the exception of Receiver E and Receiver N. These two receivers exceeded the maximum allowable noise contribution by 1dBA each, after a 5dBA low frequency noise modification factor. Further, it is noted that Receiver E has a negotiated agreement with Santos and Receiver N is owned by Santos. As such, the exceedance at these locations is not considered to be a non-compliance against the conditions of the approval.

As required by Condition 5.4 of the approval, please make a copy of this report available on the WPPS website by **31 May 2019**, or as otherwise agreed with the Department.

If you wish to discuss this further, please contact Heidi Watters, Senior Compliance Officer at the Department as per the details provided above.

Yours sincerely



09/05/19

Leah Cook

Team Leader - Compliance

As Nominee of the Secretary