

[REDACTED]
SANTOS NSW (EASTERN) PTY LTD
300 Yarrie Lake Road
Narrabri New South Wales 2390

12/01/2021

Dear [REDACTED]

**Wilga Park Power Station (MP07_0023)
Emissions Testing Report October 2020**

Reference is made to your post approval matter MP07_0023-PA-2, Emissions Testing Report (the report) for the Wilga Park Power Station (WPPS) submitted by Santos NSW (Eastern) Pty Ltd (Santos) in accordance with Schedule 2, Condition 3.2 of MP 07_0023 as modified (the approval), to the Department of Planning, Industry and Environment (the Department) on 13 November 2020.

The Department has reviewed the report and considers it to generally satisfy the conditions of approval. The Department notes the following:

- Emissions testing was undertaken in September 2020 following Santos operating the WPPS above 16MW for the first time on 13 July 2020, in accordance with Schedule 2 Condition 3.2 of the approval;
- Emissions testing was undertaken on 15-16 September 2020 to determine compliance with Schedule 2 Condition 2.4, 3.1 and 3.2 of the approval;
- Engines GO4B and GO5A were offline due to major service works and were not tested; and
- All tested locations were compliant with the discharge limits as described in Schedule 2 Condition 2.4 of the approval.

As required by Condition 5.4 of the approval, please make a copy of this report available on the project website by **19 January 2021**.

If you wish to discuss the matter further, please contact [REDACTED] Senior Compliance Officer, on (02) 6575 3419 or via email compliance@planning.nsw.gov.au

Yours sincerely



[REDACTED]
A/Team Leader - Northern
Compliance

As nominee of the Planning Secretary