

NSW Planning ref: MP07\_0023-PA-6

██████████  
Environmental Advisor  
Santos NSW (Eastern) Pty Ltd  
32 Turbot Street  
Brisbane City NSW 4000

05/12/2023

---

Sent via the Major Projects Portal only

Subject: Wilga Park Power Station - S2C3.2 WPPS Emissions Testing Report 2023

Dear ██████████

Reference is made to your post approval matter, MP07\_0023-PA-6, S2C3.2 WPPS Emissions Testing Report 2023, submitted as required by Schedule 2, Condition 3.1 of MP07\_0023 as modified (the approval) to the NSW Department of Planning and Environment (NSW Planning) on 27 November 2023.

NSW Planning will has reviewed the S2C3.2 WPPS Emissions Testing Report 2023 and considers it to generally satisfy the conditions of approval. NSW Planning notes the following:

- Emissions testing was undertaken on 24-26 October 2023 to determine compliance with Schedule 2, Condition 2.4 of the approval (discharge limits).
- Engine GO3B was offline for a 60k hour service occurring during the testing window.
- All tested locations were compliant with the discharge limit described in Schedule 2, Condition 2.4 of the approval.

In accordance with Schedule 2, Condition 5.4 of the approval, please make publicly available a copy of the S2C3.2 WPPS Emissions Testing Report 2023 on the project website by COB **22 December 2023**.

Should you wish to discuss the matter further, please contact ██████████ Senior Compliance Officer on ██████████ or email [compliance@planning.nsw.gov.au](mailto:compliance@planning.nsw.gov.au)

Yours sincerely



Heidi Watters  
Team Leader Northern  
Compliance

As nominee of the Planning Secretary