

**Santos Limited, Wilga Park
Emission Testing Report
Report Number R012308**

Document Information

Template Version 211117

Client Name: Santos Limited
Report Number: R012308
Date of Issue: 22 March 2022
Attention: Abigail Kahi
Address: Level 22, 32 Turbot Street
Brisbane QLD 4000
Testing Laboratory: Ektimo Pty Ltd, ABN 86 600 381 413

Report Authorisation



Aaron Davis
Ektimo Signatory

NATA Accredited Laboratory
No. 14601

Accredited for compliance with ISO/IEC 17025 - Testing. NATA is a signatory to the ILAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports.

This document is confidential and is prepared for the exclusive use of Santos Limited and those granted permission by Santos Limited.
The report shall not be reproduced except in full.

Please note that only numerical results pertaining to measurements conducted directly by Ektimo are covered by Ektimo's terms of NATA accreditation. This does not include comments, conclusions or recommendations based upon the results. Refer to 'Test Methods' for full details of testing covered by NATA accreditation.

Table of Contents

1	Executive Summary	4
1.1	Background	4
1.2	Project Objective	4
1.3	Results Summary	5
2	Results	6
2.1	GO3B.....	6
2.2	GO4B.....	7
2.3	GO5B.....	8
2.4	GO6B.....	9
2.5	GO2A.....	10
2.6	GO5A.....	11
2.7	GO6A.....	12
2.8	GO1A.....	13
2.9	GO3A.....	13
3	Plant Operating Conditions	15
4	Test Methods.....	15
5	Quality Assurance/Quality Control Information	16
7	Definitions	17
8	Appendix 1: Gas Calibration Certificates.....	18
9	Appendix 2. Sampling locations	20

1 Executive Summary

1.1 Background

Ektimo was engaged by Santos Limited to perform emission testing from gas-fired engines situated at their Wilga Park plant.

1.2 Project Objective

The objectives of the project were to conduct a monitoring programme to quantify emissions from multiple discharge points to determine compliance with Santos Limited's Development Approval DA07-0023.

Monitoring was performed as follows:

Location	Test Date	Test Parameters*
GO3B	7 December 2021	Nitrogen oxides (as NO ₂) Oxygen
GO4B		
GO5B		
GO6B		
GO2A	8 December 2021	
GO5A		
GO6A		
GO1A	17 March 2022	
GO3A		

* Flow rate, velocity, temperature and moisture were also determined.

Emission testing was conducted on all engines at Wilga Park that were operational on the designated occasion for monitoring.

Engine GO4A was offline due to mechanical issues during both the December 2021 and March 2022 testing occasions and was not tested.

All results are reported on a dry basis at STP.

Plant operating conditions have been noted in the report.

1.3 Results Summary

The following licence comparison table shows that all analytes highlighted in green are within the licence limit set by the Department of Planning DA 07_0023.

Location Description	Pollutant	Units	Department Planning limit	Detected values	Corrected to 3% O ₂
G01A	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	260	430
G02A	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	220	420
G03A	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	290	430
G03B	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	230	430
G04B	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	230	420
G05A	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	230	350
G05B	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	220	420
G06A	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	230	350
G06B	Oxides of Nitrogen (as NO ₂)	mg/m ³	450	220	430

Please note that the measurement uncertainty associated with the test results was not considered when determining whether the results were compliant or non-compliant.

Refer to the Test Methods table for the measurement uncertainties.

2 Results

2.1 GO3B

Date	7/12/2021	Client	Santos Limited
Report	R011119	Stack ID	GO3B
Licence No.	DA 07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 3000kW		

211203

Sampling Plane Details

Sampling plane dimensions	600 mm
Sampling plane area	0.283 m ²
Sampling port size, number	4" Flange (x2)
Access & height of ports	Elevated work platform 10 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 8 D
Upstream disturbance	Change in diameter 3 D
No. traverses & points sampled	2 12
Sample plane compliance to AS4323.1 (1995)	Compliant but non-ideal

The sampling plane is deemed to be non-ideal due to the following reasons:

The sampling plane is too near to the upstream disturbance but is greater than or equal to 2D

Stack Parameters

Moisture content, %v/v	8.4	
Gas molecular weight, g/g mole	28.5 (wet)	29.5 (dry)
Gas density at STP, kg/m ³	1.27 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m ³	0.52	
% Oxygen correction & Factor	3 %	1.89

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1115 & 1225
Temperature, °C	372
Temperature, K	646
Velocity at sampling plane, m/s	37
Volumetric flow rate, actual, m ³ /s	11
Volumetric flow rate (wet STP), m ³ /s	4.3
Volumetric flow rate (dry STP), m ³ /s	4
Mass flow rate (wet basis), kg/hour	20000

Gas Analyser Results

Sampling time	Average		
	1123 - 1222		
Combustion Gases	Corrected to		
	Concentration	3% O ₂	Mass Rate
Nitrogen oxides (as NO ₂)	mg/m ³	mg/m ³	g/min
	230	430	54
Oxygen	Concentration		
	%v/v		
	11.4		

2.2 GO4B

Date	7/12/2021	Client	Santos Limited
Report	R011119	Stack ID	GO4B
Licence No.	DA 07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 3000kW		

211203

Sampling Plane Details

Sampling plane dimensions	600 mm
Sampling plane area	0.283 m ²
Sampling port size, number	4" Flange (x2)
Access & height of ports	Elevated work platform 10 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 8 D
Upstream disturbance	Change in diameter 3 D
No. traverses & points sampled	2 12
Sample plane compliance to AS4323.1 (1995)	Compliant but non-ideal

The sampling plane is deemed to be non-ideal due to the following reasons:

The sampling plane is too near to the upstream disturbance but is greater than or equal to 2D

Stack Parameters

Moisture content, %v/v	8.5	
Gas molecular weight, g/g mole	28.6 (wet)	29.5 (dry)
Gas density at STP, kg/m ³	1.27 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m ³	0.52	
% Oxygen correction & Factor	3 %	1.82

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1430 & 1540
Temperature, °C	376
Temperature, K	650
Velocity at sampling plane, m/s	38
Volumetric flow rate, actual, m ³ /s	11
Volumetric flow rate (wet STP), m ³ /s	4.3
Volumetric flow rate (dry STP), m ³ /s	4
Mass flow rate (wet basis), kg/hour	20000

Gas Analyser Results

Sampling time	Average		
	1434 - 1533		
Combustion Gases	Corrected to		
	Concentration mg/m ³	3% O ₂ mg/m ³	Mass Rate g/min
Nitrogen oxides (as NO ₂)	230	420	55
Oxygen	Concentration		
	%v/v		
	11.1		

2.3 G05B

Date	7/12/2021	Client	Santos Limited
Report	R011119	Stack ID	G05B
Licence No.	DA 07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 3000kW		

211203

Sampling Plane Details

Sampling plane dimensions	600 mm
Sampling plane area	0.283 m ²
Sampling port size, number	4" Flange (x2)
Access & height of ports	Elevated work platform 10 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 8 D
Upstream disturbance	Change in diameter 3 D
No. traverses & points sampled	2 12
Sample plane compliance to AS4323.1 (1995)	Compliant but non-ideal

The sampling plane is deemed to be non-ideal due to the following reasons:

The sampling plane is too near to the upstream disturbance but is greater than or equal to 2D

Stack Parameters

Moisture content, %v/v	8.2	
Gas molecular weight, g/g mole	27.7 (wet)	28.6 (dry)
Gas density at STP, kg/m ³	1.24 (wet)	1.28 (dry)
Gas density at discharge conditions, kg/m ³	0.52	
% Oxygen correction & Factor	3 %	1.94

Gas Flow Parameters

Flow measurement time(s) (hhmm)	0945 & 1050
Temperature, °C	360
Temperature, K	634
Velocity at sampling plane, m/s	37
Volumetric flow rate, actual, m ³ /s	10
Volumetric flow rate (wet STP), m ³ /s	4.4
Volumetric flow rate (dry STP), m ³ /s	4
Mass flow rate (wet basis), kg/hour	20000

Gas Analyser Results	Sampling time	Average		
		0948 - 1047		
Combustion Gases		Corrected to		
		Concentration	3% O ₂	Mass Rate
		mg/m ³	mg/m ³	g/min
Nitrogen oxides (as NO ₂)		220	420	53
		Concentration		
		%v/v		
Oxygen		11.7		

2.4 GO6B

Date	7/12/2021	Client	Santos Limited
Report	R011119	Stack ID	GO6B
Licence No.	DA 07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 3000kW		

211203

Sampling Plane Details

Sampling plane dimensions	600 mm
Sampling plane area	0.283 m ²
Sampling port size, number	4" Flange (x2)
Access & height of ports	Elevated work platform 10 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 8 D
Upstream disturbance	Change in diameter 3 D
No. traverses & points sampled	2 12
Sample plane compliance to AS4323.1 (1995)	Compliant but non-ideal

The sampling plane is deemed to be non-ideal due to the following reasons:

The sampling plane is too near to the upstream disturbance but is greater than or equal to 2D

Stack Parameters

Moisture content, %v/v	8.6	
Gas molecular weight, g/g mole	28.5 (wet)	29.5 (dry)
Gas density at STP, kg/m ³	1.27 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m ³	0.53	
% Oxygen correction & Factor	3 %	1.95

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1305 & 1410
Temperature, °C	362
Temperature, K	635
Velocity at sampling plane, m/s	37
Volumetric flow rate, actual, m ³ /s	11
Volumetric flow rate (wet STP), m ³ /s	4.4
Volumetric flow rate (dry STP), m ³ /s	4
Mass flow rate (wet basis), kg/hour	20000

Gas Analyser Results		Average		
	Sampling time	1310 - 1409		
		Corrected to		
		Concentration	3% O ₂	Mass Rate
		mg/m ³	mg/m ³	g/min
Combustion Gases				
Nitrogen oxides (as NO ₂)		220	430	53
		Concentration		
		%v/v		
Oxygen		11.7		

2.5 GO2A

Date	8/12/2021	Client	Santos Limited
Report	R011119	Stack ID	GO2A
Licence No.	DA 07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 3000kW		

2.11203

Sampling Plane Details

Sampling plane dimensions	600 mm
Sampling plane area	0.283 m ²
Sampling port size, number	4" Flange (x2)
Access & height of ports	Elevated work platform 10 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 8 D
Upstream disturbance	Change in diameter 3 D
No. traverses & points sampled	2 12
Sample plane compliance to AS4323.1 (1995)	Compliant but non-ideal

The sampling plane is deemed to be non-ideal due to the following reasons:

The sampling plane is too near to the upstream disturbance but is greater than or equal to 2D

Stack Parameters

Moisture content, %v/v	8.6	
Gas molecular weight, g/g mole	28.5 (wet)	29.5 (dry)
Gas density at STP, kg/m³	1.27 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m³	0.52	
% Oxygen correction & Factor	3 %	1.90

Gas Flow Parameters

Flow measurement time(s) (hhmm)	0850 & 0910
Temperature, °C	368
Temperature, K	641
Velocity at sampling plane, m/s	37
Volumetric flow rate, actual, m ³ /s	11
Volumetric flow rate (wet STP), m ³ /s	4.4
Volumetric flow rate (dry STP), m ³ /s	4
Mass flow rate (wet basis), kg/hour	20000

Gas Analyser Results

Sampling time	Average		
	0900 - 0959		
Combustion Gases	Corrected to		
	Concentration mg/m ³	3% O ₂ mg/m ³	Mass Rate g/min
Nitrogen oxides (as NO ₂)	220	420	53
Oxygen	Concentration		
	%v/v		
	11.5		

2.6 G05A

Date	8/12/2021	Client	Santos Limited
Report	R011119	Stack ID	G05A
Licence No.	DA 07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 1000kW		

211203

Sampling Plane Details

Sampling plane dimensions	320 mm
Sampling plane area	0.0804 m ²
Sampling port size, number	Sampled at exit
Access & height of ports	Platform ladder 4 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	2 8
Sample plane compliance to AS4323.1 (1995)	Non-compliant

The sampling plane is deemed to be non-compliant due to the following reasons:

The downstream disturbance is <1D from the sampling plane

The upstream disturbance is <2D from the sampling plane

The stack or duct does not have the required number of access holes (ports)

Stack Parameters

Moisture content, %v/v	8.9	
Gas molecular weight, g/g mole	28.6 (wet)	29.6 (dry)
Gas density at STP, kg/m ³	1.28 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m ³	0.46	
% Oxygen correction & Factor	3 %	1.51

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1215 & 1325
Temperature, °C	455
Temperature, K	728
Velocity at sampling plane, m/s	40
Volumetric flow rate, actual, m ³ /s	3.2
Volumetric flow rate (wet STP), m ³ /s	1.2
Volumetric flow rate (dry STP), m ³ /s	1.1
Mass flow rate (wet basis), kg/hour	5400

Gas Analyser Results

Sampling time	Average		
	1215 - 1314		
Combustion Gases	Corrected to		
	Concentration mg/m ³	3% O ₂ mg/m ³	Mass Rate g/min
Nitrogen oxides (as NO ₂)	230	350	15
Oxygen	Concentration %v/v		
	9		

2.7 GO6A

Date	8/12/2021	Client	Santos Limited
Report	R011119	Stack ID	GO6A
Licence No.	DA 07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 1000kW		

211203

Sampling Plane Details

Sampling plane dimensions	320 mm
Sampling plane area	0.0804 m ²
Sampling port size, number	Sampled at exit
Access & height of ports	Platform ladder 4 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	2 8
Sample plane compliance to AS4323.1 (1995)	Non-compliant

The sampling plane is deemed to be non-compliant due to the following reasons:

The downstream disturbance is <1D from the sampling plane
The upstream disturbance is <2D from the sampling plane
The stack or duct does not have the required number of access holes (ports)

Stack Parameters

Moisture content, %v/v	8.8	
Gas molecular weight, g/g mole	28.6 (wet)	29.6 (dry)
Gas density at STP, kg/m ³	1.28 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m ³	0.43	
% Oxygen correction & Factor	3 %	1.52

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1035 & 1145
Temperature, °C	516
Temperature, K	789
Velocity at sampling plane, m/s	45
Volumetric flow rate, actual, m ³ /s	3.6
Volumetric flow rate (wet STP), m ³ /s	1.2
Volumetric flow rate (dry STP), m ³ /s	1.1
Mass flow rate (wet basis), kg/hour	5600

Gas Analyser Results

	Sampling time	Average		
		1040 - 1139		
Combustion Gases		Corrected to		
		Concentration mg/m ³	3% O ₂ mg/m ³	Mass Rate g/min
Nitrogen oxides (as NO ₂)		230	350	15
Oxygen		Concentration		
		%v/v		
		9.1		

2.8 GO1A

Date	17/03/2022	Client	Santos Limited
Report	R012308	Stack ID	GO1A
Licence No.	DA07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 3000kW		220315

Sampling Plane Details

Sampling plane dimensions	600 mm
Sampling plane area	0.283 m ²
Sampling port size, number	Sampled at exit
Access & height of ports	Elevated work platform 10 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 8 D
Upstream disturbance	Change in diameter 3 D
No. traverses & points sampled	2 16
Sample plane conformance to AS4323.1 (2021)	Conforming but non-ideal

The sampling plane is deemed to be non-ideal due to the following reasons:

The sampling plane is too near to the upstream disturbance but is greater than or equal to 2D

Stack Parameters

Moisture content, %v/v	8.5	
Gas molecular weight, g/g mole	28.5 (wet)	29.5 (dry)
Gas density at STP, kg/m ³	1.27 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m ³	0.50	
% Oxygen correction & Factor	3 %	1.68

Gas Flow Parameters

Flow measurement time(s) (hhmm)	1200 & 1320
Temperature, °C	400
Temperature, K	673
Velocity at sampling plane, m/s	36
Volumetric flow rate, actual, m ³ /s	10
Volumetric flow rate (wet STP), m ³ /s	4
Volumetric flow rate (dry STP), m ³ /s	3.7
Mass flow rate (wet basis), kg/hour	18000

Gas Analyser Results

Sampling time	Average		
	1207 - 1306		
Combustion Gases	Concentration	Corrected	Mass Rate
	mg/m ³	to 3% O ₂ mg/m ³	g/min
Nitrogen oxides (as NO ₂)	260	430	56
Oxygen		Concentration %v/v	
		10.2	

2.9 GO3A

Date	17/03/2022	Client	Santos Limited
Report	R012308	Stack ID	GO3A
Licence No.	DA07_0023	Location	Wilga Park
Ektimo Staff	Aaron Davis / Scott Woods	State	NSW
Process Conditions	Engine operating at 1000kW		

220315

Sampling Plane Details

Sampling plane dimensions	320 mm
Sampling plane area	0.0804 m ²
Sampling port size, number	Sampled at exit
Access & height of ports	Platform ladder 4 m
Duct orientation & shape	Vertical Circular
Downstream disturbance	Exit 0 D
Upstream disturbance	Exit 0 D
No. traverses & points sampled	2 8
Sample plane conformance to AS4323.1 (2021)	Non-conforming

The sampling plane is deemed to be non-conforming due to the following reasons:

The downstream disturbance is <1D from the sampling plane
The upstream disturbance is <2D from the sampling plane
The stack or duct does not have the required number of access holes (ports)

Stack Parameters

Moisture content, %v/v	8.9	
Gas molecular weight, g/g mole	28.5 (wet)	29.5 (dry)
Gas density at STP, kg/m ³	1.27 (wet)	1.32 (dry)
Gas density at discharge conditions, kg/m ³	0.44	
% Oxygen correction & Factor	3 %	1.48

Gas Flow Parameters

Flow measurement time(s) (hhmm)	0910 & 1030
Temperature, °C	490
Temperature, K	764
Velocity at sampling plane, m/s	48
Volumetric flow rate, actual, m ³ /s	3.9
Volumetric flow rate (wet STP), m ³ /s	1.4
Volumetric flow rate (dry STP), m ³ /s	1.2
Mass flow rate (wet basis), kg/hour	6200

Gas Analyser Results

Sampling time	Average		
	0924 - 1023		
Combustion Gases	Corrected to		
	Concentration mg/m ³	3% O ₂ mg/m ³	Mass Rate g/min
Nitrogen oxides (as NO ₂)	290	430	22
Oxygen	Concentration %v/v		
	8.8		

3 Plant Operating Conditions

The below plant operating conditions have been supplied by Santos Limited personnel.

Location	Test Date	Engine Operating Conditions
GO3B	7 December 2021	3000kW
GO4B		3000kW
GO5B		3000kW
GO6B		3000kW
GO2A	8 December 2021	3000kW
GO5A		1000kW
GO6A		1000kW
GO1A	17 March 2022	3000kW
GO3A		1000kW

4 Test Methods

All sampling and analysis performed by Ektimo unless otherwise specified. Specific details of the methods are available upon request.

Parameter	Sampling Method	Analysis Method	Uncertainty*	NATA Accredited	
				Sampling	Analysis
Sampling points - Selection	NSW EPA TM-1	NA	NA	✓	NA
Flow rate, temperature and velocity	NSW EPA TM-2	NSW EPA TM-2	8%, 2%, 7%	NA	✓
Moisture content	NSW EPA TM-22	NSW EPA TM-22	19%	✓	✓
Molecular weight	NA	NSW EPA TM-23	not specified	NA	✓
Dry gas density	NA	NSW EPA TM-23	not specified	NA	✓
Nitrogen oxides	NSW EPA TM-11	NSW EPA TM-11	12%	✓	✓
Oxygen	NSW EPA TM-25	NSW EPA TM-25	13%	✓	✓

220302

* Uncertainties cited in this table are estimated using typical values and are calculated at the 95% confidence level (coverage factor = 2).

5 Quality Assurance/Quality Control Information

Ektimo is accredited by the National Association of Testing Authorities (NATA) for the sampling and analysis of air pollutants from industrial sources. Unless otherwise stated test methods used are accredited with the National Association of Testing Authorities. For full details, search for Ektimo at NATA's website www.nata.com.au.

Ektimo is accredited by NATA (National Association of Testing Authorities) to ISO/IEC 17025 - Testing. ISO/IEC 17025 - Testing requires that a laboratory have adequate equipment to perform the testing, as well as laboratory personnel with the competence to perform the testing. This quality assurance system is administered and maintained by the Quality Director.

NATA is a member of APAC (Asia Pacific Accreditation Co-operation) and of ILAC (International Laboratory Accreditation Co-operation). Through mutual recognition arrangements with these organisations, NATA accreditation is recognised worldwide.

6 Compliance Summary

Emissions monitoring was performed on each release point for a minimum of 60 minutes.

The measured parameters were found to be below the emission limits specified in the Santos Development Approval DA07-0023.


Location	Compliant/non compliant with approval conditions
• GO3B	Compliant
• GO4B	Compliant
• GO5B	Compliant
• GO6B	Compliant
• GO2A	Compliant
• GO5A	Compliant
• GO6A	Compliant
• GO1A	Compliant
• GO3A	Compliant

7 Definitions

The following symbols and abbreviations may be used in this test report:

% v/v	Volume to volume ratio, dry or wet basis
~	Approximately
<	Less than
>	Greater than
≥	Greater than or equal to
APHA	American Public Health Association, Standard Methods for the Examination of Water and Waste Water
AS	Australian Standard
BSP	British standard pipe
CARB	Californian Air Resources Board
CEM/CEMS	Continuous Emission Monitoring/Continuous Emission Monitoring System
CTM	Conditional test method
D	Duct diameter or equivalent duct diameter for rectangular ducts
DECC	Department of Environment & Climate Change (NSW)
Disturbance	A flow obstruction or instability in the direction of the flow which may impede accurate flow determination. This includes centrifugal fans, axial fans, partially closed or closed dampers, louvres, bends, connections, junctions, direction changes or changes in pipe diameter.
EPA	Environment Protection Authority
FTIR	Fourier Transform Infra-red
ISC	Intersociety Committee, Methods of Air Sampling and Analysis
ISO	International Organisation for Standardisation
ITE	Individual threshold estimate
Lower bound	When an analyte is not present above the detection limit, the result is assumed to be equal to zero.
Medium bound	When an analyte is not present above the detection limit, the result is assumed to be equal to half of the detection limit.
NA	Not applicable
NATA	National Association of Testing Authorities
NIOSH	National Institute of Occupational Safety and Health
NT	Not tested or results not required
OM	Other approved method
PSA	Particle size analysis. PSA provides a distribution of geometric diameters, for a given sample, determined using laser diffraction.
RATA	Relative accuracy test audit
STP	Standard temperature and pressure. Gas volumes and concentrations are expressed on a dry basis at 0°C, at discharge oxygen concentration and an absolute pressure of 101.325 kPa, unless otherwise specified.
TM	Test method
TOC	The sum of all compounds of carbon which contain at least one carbon-to-carbon bond, plus methane and its derivatives.
USEPA	United States Environmental Protection Agency
VDI	Verein Deutscher Ingenieure (Association of German Engineers)
Velocity difference	The percentage difference between the average of initial flows and after flows.
XRD	X-ray diffractometry
Upper bound	When an analyte is not present above the detection limit, the result is assumed to be equal to the detection limit.
95% confidence interval	Range of values that contains the true result with 95% certainty. This means there is a 5% risk that the true result is outside this range.

8 Appendix 1: Gas Calibration Certificates



CERTIFIED REFERENCE MATERIAL CERTIFICATE OF ANALYSIS

Coregas Pty Ltd

Page 1

Prod. Order No. LGP018699
 Prod. Order Batch No. LGP018699-4
 Cylinder Serial No. 660107
 Cylinder Capacity 11 L
 Customer No. : 10032487
 Customer : EKTIMO PTY LTD
 Order No. : SO02533105

Certificate No. QCSPC027296
 Date Certified 31/05/21
 Analyst Name Jason Yap
 Mixture Type Gas
 Cylinder Content 1.6 m3
 Valve Type BS14

Component	Required Concentration	Actual Concentration	Concentration Unit of Measure	Measurement Uncertainty	Method
Nitric Oxide	100	104.9	ppm mol	2% rel	8085 Chemi-luminescence
Sulphur Dioxide	100	104.0	ppm mol	2% rel	7094 NDIRUltramat
Carbon Monoxide	100	100.1	ppm mol	2% rel	7050 NDIRS710
Carbon Dioxide	20	20.12	% mol	1% rel	7050 NDIRS710
Nitrogen		Balance			

All concentration are expressed on mole fraction basis.

The certified values are traceable to Australian National Standards of mass and thus to the International System of Units (SI).
 The certified gas mixture is typically for calibration of instruments. Measurement Uncertainty is calculated using a coverage factor K=2, which gives 95% Confidence Interval.

Technical Note :

Filling Pressure	150	BAR
Min. Useable Pressure	5	BAR
Min. Storage Temperature	10	C
Period of Validity	3 Years	

Analyst

Jason Yap
Chemist

NATA Signatory

Mark Qin
Manager Spec. Gas Lab



ACCREDITED FOR
TECHNICAL
COMPETENCE

Accredited Reference Material Producer
 Number: 12803
 Site Number: 15135


Accredited for compliance with ISO17034

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of reference material certificates

<CMS-10-SOP-8115-F3 Approved by SG&QC Manager 13/10/2020>

Print Date: 31/05/21

---End of Document---





CERTIFIED REFERENCE MATERIAL CERTIFICATE OF ANALYSIS

Coregas Pty Ltd

Page 1

Prod. Order No. LGP018944
Prod. Order Batch No. LGP018944-1
Cylinder Serial No. 660075
Cylinder Capacity 11 L
Customer No.: 10032487
Customer: EKTIMO PTY LTD
Order No.: SO02584574

Certificate No. QCSPC027747
Date Certified 05/08/21
Analyst Name Victor Sun
Mixture Type Gas
Cylinder Content 1.5m3
Valve Type BS14

Component	Required Concentration	Actual Concentration	Concentration Unit of Measure	Measurement Uncertainty	Method
Nitrogen Dioxide	50	51.4	ppm mol	5% rel	8085 Chemi-luminescence
Nitrogen		Balance			
Comments: Mixture contains 1% of oxygen for nitrogen dioxide stability.					

All concentration are expressed on mole fraction basis.
The certified values are traceable to Australian National Standards of mass and thus to the International System of Units (SI).
The certified gas mixture is typically for calibration of instruments. Measurement Uncertainty is calculated using a coverage factor K=2, which gives 95% Confidence Interval.

Technical Note:

Filling Pressure	150	BAR
Min. Useable Pressure	5	BAR
Min. Storage Temperature	10	C
Period of Validity	2 Years	

Analyst

Victor Sun
Chemist

NATA Signatory

Mark Qin
Manager Spec. Gas Lab



ACCREDITED FOR
**TECHNICAL
COMPETENCE**

Accredited Reference Material Producer
Number: 12803
Site Number: 15135

Accredited for compliance with ISO17034
NATA is a signatory to the ILAC Mutual Recognition
Arrangement for the mutual recognition of the equivalence
of reference material certificates

<CMS-10-SOP-8115-F3 Approved by SG&QC Manager 13/10/2020>

Print Date: 05/08/21

---End of Document---

Coregas Pty Ltd
66 Loftus Road, Yennora NSW 2161, Australia
Phone: (+61) 1800 807 203 coregas.com.au

9 Appendix 2. Sampling locations



GO 1A, 2A, 3B, 4B, 5B, 6B



GO 3A, 5A, 6A

Ektimo

ektimo.com.au

1300 364 005

MELBOURNE (Head Office)

26 Redland Drive

Mitcham

VIC 3132

AUSTRALIA

SYDNEY

6/78 Reserve Road,

Artarmon

NSW 2064

AUSTRALIA

WOLLONGONG

1/251 Princes Highway

Unanderra

NSW 2526

AUSTRALIA

PERTH

52 Cooper Road

Cockburn Central

WA 6164

AUSTRALIA

BRISBANE

3/109 Riverside Place

Morningside

QLD 4170

AUSTRALIA